

UTILITY CONNECTION SEWER

GENERAL NOTES:

1. All sewer connections/installations shall comply with the adopted Uniformed Plumbing Code. Connections to the drain line shall be gas-tight and watertight.
2. Each manufactured dwelling shall be connected to the sewer inlet by the means of a drain connector consisting of approved pipe and fittings, not less than schedule 40- and no smaller in diameter than 3-inches.
3. Drain pipe shall be sloped $\frac{1}{4}$ -inch per foot and supported at 4-foot intervals by approved means (minimum 3-inch pipe).
4. An approved type of two-way cleanout shall be installed on the drain line, an 18-inch clearance directly in front of the clean-out opening that extends above grade is required.
5. If located under a home, the clean out shall be no more than 20-feet from an access door or crawl hole.
6. Drainpipe shall be installed a minimum of 12-inches below grade.