

UTILITY CONNECTION

WATER

GENERAL NOTES:

1. Water pipe and fittings shall be approved material per The Uniform Plumbing Code such as: Copper, Galvanized malleable iron, Galvanized steel and approved Plastic pipe.
2. The following plastic pipe: PB, PE, or PVC, shall not be installed under any manufactured home (only PVC or better).
3. Manufactured home shall be connected to water service outlet by a flexible connector; such as copper tubing or other approved material.
4. Fullway gate shutoff valve shall be installed on the discharged side of the water meter. Access must be provided to shutoff valve.
5. Water piping outside the home shall be protected from freezing. Pipes under the unit supported at 3 foot intervals maximum.
6. Water service yard piping shall be minimum of twelve (12) inches below grade, or at least twelve (12) inches below local frost depth.
7. Potable water outlets shall be protected by a listed non-removable bibb type back-flow preventer.